

Andrew Krause

From: Andrew Krause
Sent: Wednesday, April 17, 2024 10:42 AM
To: 'Greg Frederick'
Subject: RE: [External] Re: Fence layouts and heights

Yes, once you have it all worked out, please label it on the survey all the height locations.

Thank you

Andy Krause

Code Enforcement Officer
Building & Safety Division
City of Wauwatosa
7725 W. North Avenue
Wauwatosa, WI 53213
414-479-8981

Akrause@wauwatosa.net

<https://munisselfservice.wauwatosa.net/css/default.aspx>

From: Greg Frederick <gregfreder@gmail.com>
Sent: Wednesday, April 17, 2024 10:40 AM
To: Andrew Krause <akrause@wauwatosa.net>
Cc: Kelly Frederick Mizer <kellymizer@gmail.com>
Subject: Re: [External] Re: Fence layouts and heights

OK. Thanks, Andy.

Just for your information, 1109 N.120th is only technically a corner lot. The next door neighbor's house faces Christine ST but is immediately behind and next door to 1109 N. 120th.

I am not sure if that makes any difference with respect to permit requirements.

The proposed fence will not border either 120th or Christine streets.

Once the contractor and I have decided on the area for the 4 1/2" for fence, will you need another diagram?

Greg

On Apr 16, 2024, at 2:09 PM, Andrew Krause <akrause@wauwatosa.net> wrote:

Unfortunately that is not permitted. Lattice will be considered part of the fence. The fence has a max height of 4'-6" above grade

Andy Krause

Code Enforcement Officer
Building & Safety Division
City of Wauwatosa

7725 W. North Avenue
Wauwatosa, WI 53213
414-479-8981

Akrause@wauwatosa.net

<https://munisselfservice.wauwatosa.net/css/default.aspx>

From: Greg Frederick <gregfreder@gmail.com>

Sent: Monday, April 15, 2024 9:54 AM

To: Andrew Krause <akrause@wauwatosa.net>

Cc: Kelly Frederick Mizer <kellymizer@gmail.com>; Pat Frederick <pat.fred888@gmail.com>

Subject: [External] Re: Fence layouts and heights

Andy, I've shopped around for contractors since last we communicated about the permit for a fence at 1109 N. 120th ST.

The current contractor wanted to know if Wauwatosa would permit a 4-foot fence with a 1 foot lattice section at the top.

For both cost and aesthetic reasons, that option sounds best to me.

Is that doable?

Thanks,

Greg

On Apr 5, 2024, at 9:33 AM, Andrew Krause <akrause@wauwatosa.net> wrote:

Andy Krause

Code Enforcement Officer

Building & Safety Division

City of Wauwatosa

7725 W. North Avenue

Wauwatosa, WI 53213

414-479-8981

Akrause@wauwatosa.net

<https://munisselfservice.wauwatosa.net/css/default.aspx>